



2023 Annual Water Quality Summary Report

Prepared by:

A handwritten signature in black ink, appearing to read 'FRIEL'.

March 27, 2024

Julie Friel

Date

Manager Water Treatment

Endorsed by:

A handwritten signature in black ink, appearing to read 'ML'.

March 27, 2024

Michael Loken

Date

Acting Director, Water/Wastewater Treatment & Compliance

| | |
|--|----|
| Introduction | 3 |
| SUMMARY | 4 |
| System Specific | 6 |
| Sudbury Drinking Water System 210001111 - Wanapitei | 7 |
| Non-Compliance with Act, Regulations, Order or Approvals | 7 |
| Annual Flow Summary | 8 |
| Sudbury Drinking Water System 220003537- David Street | 8 |
| Non-Compliance with Act, Regulations, Order or Approvals | 9 |
| Annual Flow Summary | 9 |
| Sudbury Drinking Water System 220003485 - Garson | 9 |
| Non-Compliance with Act, Regulations, Order or Approvals | 10 |
| Annual Flow Summary | 11 |
| Dowling Wells and Distribution System 210001665 | 12 |
| Non-Compliance with Act, Regulations, Order or Approvals | 13 |
| Annual Flow Summary | 13 |
| Bleazard Valley/Capreol Drinking Water System-210000737 | 14 |
| Non-Compliance with Act, Regulations, Order or Approvals | 16 |
| Annual Flow Summary | 16 |
| Falconbridge Drinking Water System - 240000020 | 21 |
| Non-Compliance with Act, Regulations, Order or Approvals | 21 |
| Annual Flow Summary | 21 |
| Onaping/Levack Drinking Water System - 220003519 | 23 |
| Non-Compliance with Act, Regulations, Order or Approvals | 23 |
| Annual Flow Summary | 23 |
| Vermilion Distribution System - 260006789 | 24 |
| Non-Compliance with Act, Regulations, Order or Approvals | 25 |

Introduction

The production and delivery of potable water in Ontario is regulated by Ontario Regulation (O. Reg.) 170/03 governed by the Ministry of the Environment, Conservation and Parks (MECP) under the *Safe Drinking Water Act* (SDWA), 2002, S.O. 2002, c. 32.

The purpose of this summary report is to provide system owners and municipal council information to satisfy the regulatory reporting required under Schedule 22 titled *Summary Reports for Municipalities* of the O. Reg. 170/03 Drinking Water Systems.

The information within the report must cover the following topics of the previous calendar year from January 1st through to December 31st:

- A list of orders that were not met, the duration and any corrective actions needed.
- A brief description of the operations of the treatment systems.
- Quantities and flow rates of the water supplied during the reporting period, including monthly averages and maximum daily flows.
- A comparison of the quantities and flows to the rated capacities approved in the system performance section in the Municipal Drinking Water License (MDWL).

An Annual Water Quality Report, to fulfill Section 11 of Ontario Regulation 170/03, has been completed separately and details the drinking water quality of all the CGS owned and operated drinking water systems. This annual report is available for viewing on the City of Greater Sudbury's website.

SUMMARY

During the 2023 calendar year, the City of Greater Sudbury (CGS) operated its Drinking Water Systems (DWS) within the limits specified in all applicable Municipal Drinking Water Licenses. Surface water plants supplying the Sudbury DWS operated at less than half of permitted levels, with the Wanapitei Water Treatment Plant (WTP) averaging 46% and the David Street WTP utilizing 34% of their Permits to Take Water (PTTW) permissible total water takings. Ground water systems also operated below permitted levels with Blezard Valley-Capreol DWS at 27% (Valley) and 20% (Capreol), Falconbridge DWS at 26%, Garson DWS at 18%, Onaping DWS at 32%, and Dowling DWS at 10% of its PTTW.

As part of our ongoing commitment to provide safe, reliable drinking water while meeting the requirements of source water protection legislation, CGS continues to invest in water treatment and distribution systems to perform critical upgrades and renew aging infrastructure. These upgrades are not necessarily the result of any water quality incidents, but are completed to reduce the risk of potable water contamination as part of our Statutory Standard of Care. The regulation stipulates that water works owners will continually monitor water works performance, source water quality and review levels of treatment versus current standards and emerging technologies. For example, this standard of care has been demonstrated through the following projects:

1. The ongoing construction phase for the removal of Iron and Manganese within the Blezard Valley-Capreol system is underway with its estimated completion date to be the summer of 2024.
2. Addressing Tetrachloroethylene contaminant levels in the Garson Well Field through the planned decommissioning of existing groundwater wells and connection to the Sudbury DWS.
3. David Street HVAC system upgrades to improve air quality for employees and lessen the exposure to oxidizing chemical fumes on the plants assets.
4. David street primary membrane filtration module replacement and upgrades (1 module per year for three years).
5. Wanapitei Water Treatment Plant pump motor upgrades and filter refurbishment (1 unit per year for four years).

The MECP is responsible for the enforcement of regulations and conducts inspections of all large municipal water systems. As of this report, all CGS water systems have passed inspection with two issues identified:

1. Ongoing presence of tetrachloroethylene within the Garson Wells #1 and #3
2. Elevated levels of trihalomethanes (THMs) and halo acetic acids (HAAs) in parts of the Vermilion distribution system.

CGS and Vale continue to work together to improve the disinfection process and reduce the presence of THMs and HAAs within the Vermilion distribution system.

In 2023, twenty-six (26) adverse water quality incident (AWQI) reports were filed. Corrective actions were taken, and issues were promptly rectified and reported to the MECP as well as the Public Health Sudbury & Districts (PHSD). Twelve (12) of the AWQI were to provide information on non-compliance events and did not represent adverse water conditions. These occurrences are discussed in their respective DWS sections contained in this report.

The Community Lead Testing Initiative was implemented in 2007 as part of O. Reg. 170/03, Schedule 15.1. CGS was granted relief by the MECP from lead testing in all systems except for the Sudbury DWS, fed by the Wanapitei and David St. WTPs. These sections must continue to be sampled due to the population served by that system, not as a result of water quality. CGS continues to provide corrosion control in targeted DWS to lower residual lead levels in affected areas.

Water quality throughout all systems is monitored 24 hours a day, 365 days a year. Regular sampling schedules are followed in accordance with O. Reg. 170/03 as well as our Municipal Drinking Water Licenses and Permits. Treated water is fluoridated in all CGS systems under the direction of PHSD.

System Specific

Drinking Water Services within the City of Greater Sudbury are a combination of municipally owned and operated utilities along with the supply of purchased potable water. CGS owns and operates two surface water treatment plants servicing the Sudbury distribution systems, six groundwater well fields along with their own distribution systems and one independent distribution system conveying purchased potable water from Vale's Vermilion Water Treatment Plant.

Table 1 - Overview of the City's Water Systems

| Drinking Water System | Type of Facility | Source of Water | Communities Served |
|-------------------------------|---|---|---|
| Sudbury DWS – Wanapitei | <ul style="list-style-type: none"> Class IV Surface water conventional treatment plant Class IV Distribution system | Wanapitei River | Sudbury, Coniston, Wanapitei, Markstay, Garson West |
| Sudbury DWS - David | <ul style="list-style-type: none"> Class III Surface water Membrane Filtration Plant Class IV Distribution system | Ramsey Lake | Sudbury (West and South sections) |
| Sudbury DWS - Garson | <ul style="list-style-type: none"> Class I Wells Class II Distribution system | Groundwater | Garson East (east of Penman Dr.) |
| Dowling DWS | <ul style="list-style-type: none"> Class I Wells Class I Distribution system | Groundwater | Dowling |
| Valley DWS | <ul style="list-style-type: none"> Class I Wells Class II Distribution system | Groundwater | Valley East, Azilda, Chelmsford & Capreol |
| Falconbridge DWS | <ul style="list-style-type: none"> Class I Wells Class II Distribution system | Groundwater | Falconbridge |
| Onaping /Levack DWS | <ul style="list-style-type: none"> Class I Wells Class II Distribution system | Groundwater | Onaping & Levack |
| Vermilion Distribution System | <ul style="list-style-type: none"> Class II Distribution System | Vermilion River WTP Owned and Operated by Vale | Lively, Naughton, Whitefish, Copper Cliff, Walden Industrial Park |

Sudbury Drinking Water System 210001111 - Wanapitei

The Sudbury DWS is comprised of three different water sources: the Wanapitei Water Treatment Plant (WTP), the David WTP and the Garson Well Field.

The Wanapitei WTP is a conventional surface plant located between the towns of Coniston and Wahnapiatae. Its source water is the Wanapitei River. The plant's rated capacity is 54,000 m³/day and provides approximately sixty percent of CGS's potable water. The treatment process follows these steps:

- Raw river water is screened through coarse and fine screens. Five pumps convey the raw water several kilometers to the plant for treatment.
- Raw water is initially disinfected by chlorination and the water's pH and alkalinity are controlled by the addition of lime.
- A coagulant (alum) and flocculant (polymer) are added to remove colloidal solids that are in suspension with separation performed by gravity sedimentation of clarified water and sludge.
- Settled sludge waste is pumped to a nearby sewage lagoon for treatment and the clarified water is sent to four filters.
- Filtered water flows into a clear well where lime is added to adjust the final pH and alkalinity along with addition of a corrosion control chemical.
- Chlorine is added to ensure final disinfection of finished water and to maintain a residual disinfectant within the distribution system.
- Treated water is exposed to ultraviolet (UV) light disinfection to provide extra inactivation of pathogens and pumped east to the community of Markstay and west towards the communities of Coniston and Sudbury (via the Ellis Reservoir).

Non-Compliance with Act, Regulations, Order or Approvals

In 2023, the Wanapitei system had two Adverse Water Quality Incidents (AWQI) to report:

- Chlorine residual samples were not completed as required on one occasion. A communications outage resulted in remote readings being unavailable. An operator was dispatched to site to test for chlorine and no issues were found.
- A bacterial sample taken at a City owned facility tested positive for coliform contamination. Further testing confirmed this was an isolated incident. The tap was cleaned, resampled, and showed no contamination.

Annual Flow Summary

| Wanapitei WTP | | | | | | | |
|---------------|------------------------------|---|---|--------------------------------|---|---|------------|
| | Total Flow m ³ | Average Daily Flow m ³ /d | Maximum Daily Flow m ³ /d | Instantaneous Peak Flow L/s | MDWL Daily Maximum Permitted m ³ /d | MDWL Annual Permitted m ³ | % Capacity |
| January | 695,417 | 22,433 | 24,238 | 438.0 | 54,000 | 19,710,000 | 41.5 |
| February | 621,777 | 22,206 | 24,248 | 406.6 | 54,000 | 19,710,000 | 41.1 |
| March | 704,451 | 22,724 | 25,406 | 415.4 | 54,000 | 19,710,000 | 42.1 |
| April | 675,139 | 22,505 | 25,706 | 392.7 | 54,000 | 19,710,000 | 41.7 |
| May | 772,702 | 24,926 | 29,577 | 416.4 | 54,000 | 19,710,000 | 46.2 |
| June | 845,487 | 28,183 | 31,066 | 436.5 | 54,000 | 19,710,000 | 52.2 |
| July | 861,592 | 27,793 | 32,883 | 454.0 | 54,000 | 19,710,000 | 51.5 |
| August | 843,416 | 27,207 | 31,452 | 435.2 | 54,000 | 19,710,000 | 50.4 |
| September | 838,177 | 27,939 | 32,216 | 436.4 | 54,000 | 19,710,000 | 51.7 |
| October | 782,015 | 25,226 | 29,085 | 444.4 | 54,000 | 19,710,000 | 46.7 |
| November | 715,541 | 23,851 | 27,141 | 394.4 | 54,000 | 19,710,000 | 44.2 |
| December | 731,265 | 23,589 | 27,235 | 462.6 | 54,000 | 19,710,000 | 43.7 |
| Total | 9,086,981 | | | | 54,000 | 19,710,000 | 46.1 |

Sudbury Drinking Water System 220003537- David Street

David St. WTP is a membrane ultra-filtration surface water treatment plant. The plant's rated capacity is 40,000 m³/day and provides approximately forty percent of the City of Greater Sudbury's potable water.

The raw water intake is located approximately three hundred meters from the shores of Ramsey Lake. The treatment process follows these steps:

- Raw lake water is screened through coarse screens and two strainers and is initially disinfected by chlorination.
- Four pumps send the water to membrane trains for ultrafiltration. Where particles 0.02 microns (µm) in size or larger are removed.
- The filtered water flows into a reservoir where chlorine, as sodium hypochlorite, is added to ensure final disinfection of finished water and to maintain a residual disinfectant within the distribution system. Fluoride is added to prevent tooth decay along with a corrosion control chemical.
- The treated water is pumped through UV light disinfection units to provide extra inactivation of pathogens.

- The treated water is pumped to the distribution system by four pumps and directs water flows to the south, west and downtown sections of the City of Greater Sudbury. Water from this plant is also used to fill the Ellis Reservoir.

Non-Compliance with Act, Regulations, Order or Approvals

In 2023, the David St. system had one AWQI:

- Hourly chlorine residual samples were not completed as required on one occasion. A communications outage resulted in remote readings being unavailable. An operator was dispatched to site to test for chlorine and no issues were found.

Annual Flow Summary

| David St. WTP | | | | | | | |
|---------------|------------------------------|---|---|--------------------------------|---|---|------------|
| | Total Flow m ³ | Average Daily Flow m ³ /d | Maximum Daily Flow m ³ /d | Instantaneous Peak Flow L/s | MDWL Daily Maximum Permitted m ³ /d | MDWL Annual Permitted m ³ | % Capacity |
| January | 418,010 | 13,484 | 13,682 | 389.4 | 40,000 | 14,600,000 | 33.7 |
| February | 381,583 | 12,309 | 21,382 | 384.5 | 40,000 | 14,600,000 | 34.1 |
| March | 422,500 | 13,629 | 24,837 | 405.6 | 40,000 | 14,600,000 | 34.1 |
| April | 405,064 | 13,067 | 15,292 | 412.5 | 40,000 | 14,600,000 | 33.8 |
| May | 423,783 | 13,670 | 14,920 | 390.7 | 40,000 | 14,600,000 | 34.2 |
| June | 420,921 | 13,578 | 15,762 | 500.1 | 40,000 | 14,600,000 | 35.1 |
| July | 418,561 | 13,502 | 14,107 | 365.7 | 40,000 | 14,600,000 | 33.8 |
| August | 419,797 | 13,542 | 14,136 | 358.8 | 40,000 | 14,600,000 | 33.9 |
| September | 396,879 | 12,803 | 13,694 | 372.5 | 40,000 | 14,600,000 | 33.1 |
| October | 438,535 | 14,146 | 24,907 | 560.6 | 40,000 | 14,600,000 | 35.4 |
| November | 424,726 | 13,701 | 14,415 | 386.4 | 40,000 | 14,600,000 | 35.4 |
| December | 458,837 | 14,801 | 18,242 | 487.4 | 40,000 | 14,600,000 | 37.0 |
| Total | 5,029,197 | | | | 40,000 | 14,600,000 | 34.4 |

Sudbury Drinking Water System 220003485 - Garson

Garson is a groundwater system consisting of three wells servicing the community of Garson east of Penman Ave and O'Neil Dr East. The three wells are:

- Garson Well No. 1.
- Garson Well No. 2.

- Garson Well No. 3.

The system includes three well pumps, disinfection with sodium hypochlorite and fluoride injection as mandated by PHSD. The water is directly connected to the distribution system. The distribution system extends from Skead Road to the north to Garson-Coniston Road to the south. The community west of Penman Avenue is serviced from the Sudbury distribution system and is connected to the rest of the Garson system via a pressure actuated valve at Falconbridge Road and O'Neil Drive West. If all three wells were to fail, this valve will open supplying the eastern portion of the community with water from the Sudbury system.

In 2011, with direction and consultation from PHSD and the MECP, CGS committed to undertaking a groundwater monitoring program for tetrachloroethylene (TCE). In 2012 four monitoring wells were drilled in the area. Sampling and analysis is completed regularly by staff to augment historical data and to ensure the safety of the public. Although TCE levels found during audit sampling are well below regulatory limits, CGS is proactively sampling and monitoring these levels. In 2017 CGS retained a consultant to provide feasibility options for the Garson system. Feeding the entire community of Garson from the Sudbury system was selected as the best available option, and the upgrades required to facilitate this are currently in the detailed design phase. In the meantime, well #3 is being underutilized as it has the highest concentration of TCE.

Non-Compliance with Act, Regulations, Order or Approvals

The Garson DWS had eight AWQI to report in 2023.

- Data was not reviewed on the mandated 72-hour schedule on one occasion. Trending was completed outside this window.
- Low water pressure in the system was reported on one occasion during a main break and a boil water advisory was issued.
- Chlorine residual samples were not completed as required on one occasion. A communications outage resulted in remote readings being unavailable. An operator was dispatched to site to test for chlorine and no issues were found.
- Four (4) incidences of bacterial contamination were found in the distribution system in which it was found to be sampling mistakes. No issues were found with the water quality.
- A valve was not properly closed during maintenance activities, potentially allowing a small amount of unchlorinated water to enter the distribution system. The issue was reported to the MECP and PHSD, the system was sampled, analyzed, and no adverse water quality was noted.

Annual Flow Summary

| Garson Well #1 | | | | | | | |
|----------------|------------------------------|---|---|--------------------------------|---|---|------------|
| | Total Flow m ³ | Average Daily Flow m ³ /d | Maximum Daily Flow m ³ /d | Instantaneous Peak Flow L/s | MDWL Daily Maximum Permitted m ³ /d | MDWL Annual Permitted m ³ | % Capacity |
| January | 11,961 | 386 | 599 | 15.9 | 1,572 | 573,955 | 24.5 |
| February | 8,145 | 291 | 412 | 16.0 | 1,572 | 573,955 | 18.5 |
| March | 9,425 | 304 | 463 | 16.0 | 1,572 | 573,955 | 19.3 |
| April | 8,680 | 289 | 429 | 16.2 | 1,572 | 573,955 | 18.4 |
| May | 9,347 | 302 | 773 | 17.1 | 1,572 | 573,955 | 19.2 |
| June | 12,211 | 407 | 753 | 17.1 | 1,572 | 573,955 | 25.9 |
| July | 8,858 | 286 | 538 | 16.8 | 1,572 | 573,955 | 18.2 |
| August | 7,316 | 236 | 442 | 16.5 | 1,572 | 573,955 | 15.0 |
| September | 9,156 | 305 | 568 | 11.6 | 1,572 | 573,955 | 19.4 |
| October | 8,526 | 275 | 470 | 11.6 | 1,572 | 573,955 | 17.5 |
| November | 7,460 | 249 | 484 | 11.4 | 1,572 | 573,955 | 15.8 |
| December | 6,829 | 220 | 342 | 11.5 | 1,572 | 573,955 | 14.0 |
| Total | 107,913 | | | | 1,572 | 573,955 | 18.8 |

| Garson Well #2 | | | | | | | |
|----------------|------------------------------|---|---|--------------------------------|---|---|------------|
| | Total Flow m ³ | Average Daily Flow m ³ /d | Maximum Daily Flow m ³ /d | Instantaneous Peak Flow L/s | MDWL Daily Maximum Permitted m ³ /d | MDWL Annual Permitted m ³ | % Capacity |
| January | 13,343 | 430 | 1,060 | 40.0 | 2,981 | 1,088,065 | 14.4 |
| February | 24,171 | 863 | 1,125 | 32.3 | 2,981 | 1,088,065 | 29.0 |
| March | 26,733 | 862 | 1,230 | 30.1 | 2,981 | 1,088,065 | 28.9 |
| April | 25,850 | 862 | 1,033 | 29.7 | 2,981 | 1,088,065 | 28.9 |
| May | 29,787 | 961 | 1,708 | 32.2 | 2,981 | 1,088,065 | 32.2 |
| June | 30,765 | 1,025 | 1,562 | 40.0 | 2,981 | 1,088,065 | 34.4 |
| July | 27,823 | 898 | 1,329 | 40.0 | 2,981 | 1,088,065 | 30.1 |
| August | 26,965 | 870 | 1,247 | 37.2 | 2,981 | 1,088,065 | 29.2 |
| September | 27,053 | 902 | 1,017 | 40.0 | 2,981 | 1,088,065 | 30.3 |
| October | 27,070 | 873 | 1,042 | 26.9 | 2,981 | 1,088,065 | 29.3 |
| November | 27,156 | 905 | 1,028 | 26.1 | 2,981 | 1,088,065 | 30.4 |
| December | 24,881 | 803 | 946 | 40.0 | 2,981 | 1,088,065 | 26.9 |
| Total | 311,596 | | | | 2,981 | 1,088,065 | 28.6 |

| Garson Well #3 | | | | | | | |
|------------------|------------------------------|---|---|--------------------------------|---|---|------------|
| | Total Flow m ³ | Average Daily Flow m ³ /d | Maximum Daily Flow m ³ /d | Instantaneous Peak Flow L/s | MDWL Daily Maximum Permitted m ³ /d | MDWL Annual Permitted m ³ | % Capacity |
| January | 10,479 | 338 | 930 | 31.7 | 3,275 | 1,195,214 | 10.3 |
| February | 915 | 33 | 113 | 31.7 | 3,275 | 1,195,214 | 1.0 |
| March | 2,466 | 80 | 506 | 31.1 | 3,275 | 1,195,214 | 2.4 |
| April | 1,953 | 65 | 472 | 32.5 | 3,275 | 1,195,214 | 2.0 |
| May | 3,918 | 126 | 679 | 31.4 | 3,275 | 1,195,214 | 3.9 |
| June | 7,193 | 240 | 713 | 33.0 | 3,275 | 1,195,214 | 7.3 |
| July | 9,264 | 299 | 1,026 | 28.3 | 3,275 | 1,195,214 | 9.1 |
| August | 11,203 | 361 | 1,367 | 30.4 | 3,275 | 1,195,214 | 11.0 |
| September | 5,083 | 169 | 510 | 30.3 | 3,275 | 1,195,214 | 5.2 |
| October | 5,165 | 167 | 671 | 26.0 | 3,275 | 1,195,214 | 5.1 |
| November | 4,629 | 154 | 383 | 24.4 | 3,275 | 1,195,214 | 4.7 |
| December | 5,419 | 175 | 1,139 | 27.0 | 3,275 | 1,195,214 | 5.3 |
| Total | 67,687 | | | | 3,275 | 1,195,214 | 5.7 |

Dowling Wells and Distribution System 210001665

The water source for the Dowling wells is within the Onaping river watershed. Due to the unconfined nature of the soils and the proximity to the river, the MECP has characterized the water source as potentially groundwater under the direct influence of surface water (GUDI).

Studies were conducted in 2002 with the resulting submission of a GUDI study on July 1, 2002. This study was reviewed and accepted by the MECP and as a result, both wells were deemed to be GUDI with effective in-situ filtration. As such, the additional treatment of UV irradiation was added to enhance disinfection to comply with the treatment requirements.

The treatment process follows these steps:

The system includes two well sites. Each well site contains one well pump, disinfection with chlorine gas, UV irradiation along with fluoride injection. The elevated water storage provides a measure of security to the water system in the event of power interruptions and watermain breaks.

Non-Compliance with Act, Regulations, Order or Approvals

The Dowling DWS had two non-compliance in 2023.

- Data was not reviewed on the mandated 72-hour schedule on one occasion. Data was reviewed outside this window.
- Chlorine residual samples were not completed as required on one occasion. A communications outage resulted in remote readings being unavailable. An operator was dispatched to site to test for chlorine and no issues were found.

Annual Flow Summary

| Lionel Well | | | | | | | |
|--------------|------------------------------|---|---|--------------------------------|---|---|------------|
| | Total Flow m ³ | Average Daily Flow m ³ /d | Maximum Daily Flow m ³ /d | Instantaneous Peak Flow L/s | MDWL Daily Maximum Permitted m ³ /d | MDWL Annual Permitted m ³ | % Capacity |
| January | 5,788 | 187 | 448 | 23.1 | 3,640 | 1,328,600 | 5.1 |
| February | 4,242 | 137 | 521 | 22.3 | 3,640 | 1,328,600 | 4.2 |
| March | 4,109 | 133 | 408 | 22.3 | 3,640 | 1,328,600 | 3.6 |
| April | 7,926 | 256 | 424 | 23.1 | 3,640 | 1,328,600 | 7.3 |
| May | 6,475 | 209 | 552 | 22.7 | 3,640 | 1,328,600 | 5.7 |
| June | 6,285 | 203 | 531 | 22.3 | 3,640 | 1,328,600 | 5.8 |
| July | 6,490 | 209 | 523 | 21.9 | 3,640 | 1,328,600 | 5.8 |
| August | 5,991 | 193 | 448 | 21.0 | 3,640 | 1,328,600 | 5.3 |
| September | 6,731 | 217 | 456 | 21.0 | 3,640 | 1,328,600 | 6.2 |
| October | 7,195 | 232 | 505 | 21.4 | 3,640 | 1,328,600 | 6.4 |
| November | 6,511 | 210 | 680 | 21.9 | 3,640 | 1,328,600 | 6.0 |
| December | 6,309 | 204 | 445 | 22.3 | 3,640 | 1,328,600 | 5.6 |
| Total | 74,051 | | | | 3,640 | 1,328,600 | 5.6 |

| Riverside Well | | | | | | | |
|------------------|------------------------------|---|---|--------------------------------|---|---|------------|
| | Total Flow m ³ | Average Daily Flow m ³ /d | Maximum Daily Flow m ³ /d | Instantaneous Peak Flow L/s | MDWL Daily Maximum Permitted m ³ /d | MDWL Annual Permitted m ³ | % Capacity |
| January | 4,406 | 142 | 424 | 33.4 | 3,640 | 1,328,600 | 3.9 |
| February | 4,737 | 153 | 486 | 32.6 | 3,640 | 1,328,600 | 4.6 |
| March | 5,978 | 193 | 495 | 32.6 | 3,640 | 1,328,600 | 5.3 |
| April | 2,740 | 88 | 392 | 54.8 | 3,640 | 1,328,600 | 2.5 |
| May | 7,225 | 233 | 625 | 32.2 | 3,640 | 1,328,600 | 6.4 |
| June | 6,815 | 220 | 716 | 30.9 | 3,640 | 1,328,600 | 6.2 |
| July | 5,917 | 191 | 388 | 30.5 | 3,640 | 1,328,600 | 5.2 |
| August | 6,403 | 207 | 500 | 30.5 | 3,640 | 1,328,600 | 5.7 |
| September | 6,039 | 195 | 589 | 30.5 | 3,640 | 1,328,600 | 5.5 |
| October | 7,032 | 227 | 625 | 30.9 | 3,640 | 1,328,600 | 6.2 |
| November | 7,619 | 246 | 742 | 32.2 | 3,640 | 1,328,600 | 7.0 |
| December | 6,761 | 218 | 582 | 30.9 | 3,640 | 1,328,600 | 6.0 |
| Total | 71,672 | | | | 3,640 | 1,328,600 | 5.4 |

Bleazard Valley/Capreol Drinking Water System-210000737

In 2010, the Bleazard Valley and Capreol well supply systems were determined to be one system due to existing cross connections. As such one Municipal Drinking Water License and Works Permit has been assigned to the entire system. This report will identify the works by geographical area where appropriate.

The Bleazard Valley portion of the system is a multi-well groundwater system servicing the communities of Hanmer, Bleazard Valley, Val Therese, Val Caron, McCrea Heights, Azilda and Chelmsford. Eleven groundwater wells are situated throughout the Hanmer and Val Therese area. The communities are interconnected with distribution piping and the system feeds three water storage tanks located in Val Caron, Azilda, and Chelmsford. This well field extends approximately 7.5 km (west to east) from Val Therese to Hanmer.

Some of the wells are located immediately adjacent to residential homes, commercial establishments, and major arterial roadways. The water quality is beginning to show the effects of urbanization such as sodium residuals higher than the provincial standard. Public education sessions and bylaws have been implemented in attempts to maintain the quality of source water.

The Blezard wells are:

- Deschene well.
- Kenneth well (currently not in service).
- Philippe well.
- Frost well.
- I well (currently not in service).
- Notre Dame well.
- Linden well.
- Pharand well.
- Michelle well.
- Chenier well.
- R Well.

Each well site consists of one well pump, disinfection with chlorine gas, UV irradiation along with fluoride injection. The distribution system has been relatively reliable. It is to be noted that all the wells producing water are before the Val Caron tank. One trunk main delivers the potable water to the Val Caron Tank, the Azilda Tank and the Chelmsford Tank.

Two wells, I-Well and Kenneth well, were not used in 2023. Analysis of raw water samples has shown elevated iron and manganese that compromises the aesthetic quality of the water. Removal of these parameters is expected to be available by end of 2024 as the construction phase to add additional treatment steps is underway.

The Capreol Well portion of the system draws water from two wells to service the community of Capreol.

The Capreol wells are:

- M Well.
- J Well.

The Capreol portion of the system consists of two groundwater wells servicing the community of Capreol. They are situated on the east side of Greens Lake. Like the Dowling wells, hydrogeological studies found these wells to be potentially GUDI with effective in situ filtration and as such required UV irradiation.

Each well site consists of one well pump, disinfection with chlorine gas, UV irradiation, polyphosphate for corrosion control along with fluoride injection.

The Blezard Valley wells can supply water through the Capreol Boosters located onsite at the wells ensuring a continued water supply to the town of Capreol in the event the two wells are unavailable.

The distribution system in Capreol was developed in conjunction with the growth of industry in the area and, as such, some of the pipe network is relatively old. The frost depths in Capreol extend to extreme depths during cold winters, which impose additional stresses on the integrity of the system. A second water main was added to the distribution system from the well as a contingency.

Non-Compliance with Act, Regulations, Order or Approvals

The Blezard Valley/Capreol DWS had 2 non-compliances in 2023.

- An MECP inspection documented non-NSF certified piping. The piping was removed, and new NSF certified piping was installed.
- Data was not reviewed in the mandated 72-hour time frame on one occasion. The review was completed, and no unusual data was found.

Annual Flow Summary

Due to high iron and manganese causing aesthetic issues with the distributed water from I well and Kenneth well; they were not used in 2023. Kenneth well will be receiving a rehabilitation in 2024 in steps to return it to aesthetically pleasing parameters. I well will continue to be out of production until the manganese and iron filtration installation at M and J wells is proven to be viable.

| Well "A" Deschene | | | | | | | |
|-------------------|------------------------------|--|--|-----------------------------------|--|---|---------------|
| | Total Flow m ³ | Average Daily Flow m ³ /d | Maximum Daily Flow m ³ /d | Instantaneous Peak Flow L/s | MDWL Daily Maximum Permitted m ³ /d | MDWL Annual Permitted m ³ | % Capacity |
| January | 13,172 | 425 | 1,056 | 18.5 | 1,798 | 656,212 | 23.6 |
| February | 7 | 0 | 7 | 18.3 | 1,798 | 656,212 | 0.0 |
| March | 0 | 0 | 0 | 0.0 | 1,798 | 656,212 | 0.0 |
| April | 1,414 | 47 | 270 | 18.5 | 1,798 | 656,212 | 2.6 |
| May | 4,634 | 149 | 687 | 80.0 | 1,798 | 656,212 | 8.3 |
| June | 0 | 0 | 0 | 0.0 | 1,798 | 656,212 | 0.0 |
| July | 0 | 0 | 0 | 0.0 | 1,798 | 656,212 | 0.0 |
| August | 0 | 0 | 0 | 0.0 | 1,798 | 656,212 | 0.0 |
| September | 12 | 0 | 12 | 24.3 | 1,798 | 656,212 | 0.0 |
| October | 14,210 | 458 | 1,564 | 24.3 | 1,798 | 656,212 | 25.5 |
| November | 18,428 | 614 | 1,635 | 20.3 | 1,798 | 656,212 | 34.2 |
| December | 4,886 | 158 | 714 | 21.6 | 1,798 | 656,212 | 8.8 |
| Total | 56,762 | | | | 1,798 | 656,212 | 8.7 |

| Well "C" Philippe | | | | | | | |
|-------------------|------------------------------|--|--|-----------------------------------|--|---|---------------|
| | Total Flow m ³ | Average Daily Flow m ³ /d | Maximum Daily Flow m ³ /d | Instantaneous Peak Flow L/s | MDWL Daily Maximum Permitted m ³ /d | MDWL Annual Permitted m ³ | % Capacity |
| January | 22,890 | 738 | 1,220 | 25.1 | 2,288 | 835,178 | 32.3 |
| February | 24,604 | 879 | 1,798 | 24.4 | 2,288 | 835,178 | 38.4 |
| March | 22,141 | 714 | 1,813 | 24.6 | 2,288 | 835,178 | 31.2 |
| April | 23,323 | 777 | 1,330 | 24.6 | 2,288 | 835,178 | 34.0 |
| May | 37,694 | 1,216 | 1,883 | 24.8 | 2,288 | 835,178 | 53.1 |
| June | 28,119 | 937 | 1,623 | 25.3 | 2,288 | 835,178 | 41.0 |
| July | 22,735 | 733 | 1,195 | 25.0 | 2,288 | 835,178 | 32.1 |
| August | 25,384 | 819 | 1,447 | 25.2 | 2,288 | 835,178 | 35.8 |
| September | 25,123 | 837 | 1,841 | 24.5 | 2,288 | 835,178 | 36.6 |
| October | 26,997 | 871 | 1,883 | 24.9 | 2,288 | 835,178 | 38.1 |
| November | 20,690 | 690 | 1,783 | 25.5 | 2,288 | 835,178 | 30.1 |
| December | 26,693 | 861 | 1,820 | 24.9 | 2,288 | 835,178 | 37.6 |
| Total | 306,393 | | | | 2,288 | 835,178 | 36.7 |

| Well "D" Frost | | | | | | | |
|----------------|------------------------------|--|--|-----------------------------------|--|---|---------------|
| | Total Flow m ³ | Average Daily Flow m ³ /d | Maximum Daily Flow m ³ /d | Instantaneous Peak Flow L/s | MDWL Daily Maximum Permitted m ³ /d | MDWL Annual Permitted m ³ | % Capacity |
| January | 21,876 | 706 | 1,417 | 26.8 | 2,288 | 835,178 | 30.8 |
| February | 24,071 | 860 | 1,821 | 25.4 | 2,288 | 835,178 | 37.6 |
| March | 19,615 | 633 | 1,532 | 25.6 | 2,288 | 835,178 | 27.7 |
| April | 24,137 | 805 | 1,881 | 31.9 | 2,288 | 835,178 | 35.2 |
| May | 25,725 | 830 | 1,554 | 29.8 | 2,288 | 835,178 | 36.3 |
| June | 24,288 | 810 | 1,520 | 22.4 | 2,288 | 835,178 | 35.4 |
| July | 38,419 | 1,239 | 1,871 | 25.3 | 2,288 | 835,178 | 54.2 |
| August | 34,797 | 1,122 | 1,883 | 25.4 | 2,288 | 835,178 | 49.1 |
| September | 19,622 | 654 | 1,093 | 25.3 | 2,288 | 835,178 | 28.6 |
| October | 28,673 | 925 | 2,018 | 26.3 | 2,288 | 835,178 | 40.4 |
| November | 24,572 | 819 | 1,919 | 27.9 | 2,288 | 835,178 | 35.8 |
| December | 18,663 | 602 | 1,997 | 28.0 | 2,288 | 835,178 | 26.3 |
| Total | 304,459 | | | | 2,288 | 835,178 | 36.5 |

| Well "E" Notre Dame | | | | | | | |
|---------------------|------------------------------|--|--|-----------------------------------|--|---|---------------|
| | Total Flow m ³ | Average Daily Flow m ³ /d | Maximum Daily Flow m ³ /d | Instantaneous Peak Flow L/s | MDWL Daily Maximum Permitted m ³ /d | MDWL Annual Permitted m ³ | % Capacity |
| January | 33,080 | 1,067 | 1,940 | 36.7 | 3,105 | 1,133,456 | 34.4 |
| February | 43,309 | 1,547 | 2,811 | 36.2 | 3,105 | 1,133,456 | 49.8 |
| March | 54,582 | 1,761 | 2,798 | 36.1 | 3,105 | 1,133,456 | 56.7 |
| April | 39,180 | 1,306 | 2,583 | 35.6 | 3,105 | 1,133,456 | 42.1 |
| May | 38,220 | 1,233 | 2,781 | 36.6 | 3,105 | 1,133,456 | 39.7 |
| June | 42,242 | 1,408 | 2,807 | 36.1 | 3,105 | 1,133,456 | 45.3 |
| July | 37,786 | 1,219 | 2,891 | 80.0 | 3,105 | 1,133,456 | 39.3 |
| August | 32,327 | 1,043 | 2,907 | 37.3 | 3,105 | 1,133,456 | 33.6 |
| September | 31,844 | 1,061 | 2,317 | 31.9 | 3,105 | 1,133,456 | 34.2 |
| October | 35,628 | 1,149 | 2,513 | 32.4 | 3,105 | 1,133,456 | 37.0 |
| November | 33,251 | 1,108 | 2,559 | 32.1 | 3,105 | 1,133,456 | 35.7 |
| December | 44,028 | 1,420 | 2,514 | 32.4 | 3,105 | 1,133,456 | 45.7 |
| Total | 465,478 | | | | 3,105 | 1,133,456 | 41.1 |

| Well "F" Linden | | | | | | | |
|-----------------|------------------------------|--|--|-----------------------------------|--|---|---------------|
| | Total Flow m ³ | Average Daily Flow m ³ /d | Maximum Daily Flow m ³ /d | Instantaneous Peak Flow L/s | MDWL Daily Maximum Permitted m ³ /d | MDWL Annual Permitted m ³ | % Capacity |
| January | 45,623 | 1,472 | 2,607 | 33.7 | 3,269 | 1,193,112 | 45.0 |
| February | 43,882 | 1,567 | 2,632 | 33.7 | 3,269 | 1,193,112 | 47.9 |
| March | 48,250 | 1,556 | 2,669 | 34.4 | 3,269 | 1,193,112 | 47.6 |
| April | 40,279 | 1,343 | 2,663 | 33.1 | 3,269 | 1,193,112 | 41.1 |
| May | 35,605 | 1,149 | 1,946 | 33.2 | 3,269 | 1,193,112 | 35.1 |
| June | 43,987 | 1,466 | 2,652 | 32.7 | 3,269 | 1,193,112 | 44.9 |
| July | 44,090 | 1,422 | 2,610 | 33.2 | 3,269 | 1,193,112 | 43.5 |
| August | 36,967 | 1,192 | 1,935 | 33.1 | 3,269 | 1,193,112 | 36.5 |
| September | 33,364 | 1,112 | 2,594 | 33.5 | 3,269 | 1,193,112 | 34.0 |
| October | 45,426 | 1,465 | 2,698 | 34.4 | 3,269 | 1,193,112 | 44.8 |
| November | 50,099 | 1,670 | 2,627 | 33.0 | 3,269 | 1,193,112 | 51.1 |
| December | 48,977 | 1,580 | 2,622 | 33.1 | 3,269 | 1,193,112 | 48.3 |
| Total | 516,547 | | | | 3,269 | 1,193,112 | 43.3 |

| Well "G" Pharand | | | | | | | |
|------------------|------------------------------|--|--|---------------------------------------|--|---|---------------|
| | Total Flow m ³ | Average Daily Flow m ³ /d | Maximum Daily Flow m ³ /d | Instantaneous Peak Flow L/s | MDWL Daily Maximum Permitted m ³ /d | MDWL Annual Permitted m ³ | % Capacity |
| January | 21,227 | 685 | 2,131 | 26.3 | 2,290 | 835,704 | 29.9 |
| February | 33,072 | 1,181 | 2,139 | 26.4 | 2,290 | 835,704 | 51.6 |
| March | 22,687 | 732 | 1,525 | 29.5 | 2,290 | 835,704 | 32.0 |
| April | 25,698 | 857 | 1,521 | 28.9 | 2,290 | 835,704 | 37.4 |
| May | 28,148 | 908 | 2,116 | 29.2 | 2,290 | 835,704 | 39.7 |
| June | 30,303 | 1,010 | 1,558 | 30.0 | 2,290 | 835,704 | 44.1 |
| July | 25,452 | 821 | 1,491 | 28.8 | 2,290 | 835,704 | 35.9 |
| August | 24,451 | 789 | 1,582 | 29.7 | 2,290 | 835,704 | 34.4 |
| September | 22,168 | 739 | 1,252 | 25.4 | 2,290 | 835,704 | 32.3 |
| October | 25,134 | 811 | 1,667 | 25.3 | 2,290 | 835,704 | 35.4 |
| November | 20,283 | 676 | 1,172 | 25.0 | 2,290 | 835,704 | 29.5 |
| December | 26,263 | 847 | 1,570 | 25.6 | 2,290 | 835,704 | 37.0 |
| Total | 304,886 | | | | 2,290 | 835,704 | 36.5 |

| Well "H" Michelle | | | | | | | |
|-------------------|------------------------------|--|--|---------------------------------------|--|---|---------------|
| | Total Flow m ³ | Average Daily Flow m ³ /d | Maximum Daily Flow m ³ /d | Instantaneous Peak Flow L/s | MDWL Daily Maximum Permitted m ³ /d | MDWL Annual Permitted m ³ | % Capacity |
| January | 263 | 8 | 210 | 27.3 | 2,290 | 835,704 | 0.4 |
| February | 5,363 | 192 | 1,395 | 24.1 | 2,290 | 835,704 | 8.4 |
| March | 28,444 | 918 | 1,823 | 24.0 | 2,290 | 835,704 | 40.1 |
| April | 23,935 | 798 | 1,812 | 29.1 | 2,290 | 835,704 | 34.8 |
| May | 23,238 | 750 | 1,822 | 23.7 | 2,290 | 835,704 | 32.7 |
| June | 25,452 | 848 | 1,294 | 22.8 | 2,290 | 835,704 | 37.1 |
| July | 21,574 | 696 | 1,229 | 22.5 | 2,290 | 835,704 | 30.4 |
| August | 9,081 | 293 | 1,118 | 24.7 | 2,290 | 835,704 | 12.8 |
| September | 48,312 | 1,610 | 1,844 | 23.5 | 2,290 | 835,704 | 70.3 |
| October | 20,966 | 676 | 1,829 | 22.7 | 2,290 | 835,704 | 29.5 |
| November | 18,950 | 632 | 1,223 | 23.0 | 2,290 | 835,704 | 27.6 |
| December | 23,970 | 773 | 1,804 | 23.1 | 2,290 | 835,704 | 33.8 |
| Total | 249,548 | | | | 2,290 | 835,704 | 29.9 |

| Well "Q" Chenier | | | | | | | |
|------------------|------------------------------|--|--|---------------------------------------|--|---|---------------|
| | Total Flow m ³ | Average Daily Flow m ³ /d | Maximum Daily Flow m ³ /d | Instantaneous Peak Flow L/s | MDWL Daily Maximum Permitted m ³ /d | MDWL Annual Permitted m ³ | % Capacity |
| January | 51,602 | 1,665 | 2,076 | 26.8 | 2,333 | 851,472 | 71.4 |
| February | 35,440 | 1,266 | 2,075 | 26.7 | 2,333 | 851,472 | 54.3 |
| March | 25,325 | 817 | 2,074 | 26.9 | 2,333 | 851,472 | 35.0 |
| April | 41,778 | 1,393 | 2,075 | 26.7 | 2,333 | 851,472 | 59.7 |
| May | 35,006 | 1,129 | 2,075 | 26.4 | 2,333 | 851,472 | 48.4 |
| June | 38,658 | 1,289 | 2,075 | 26.4 | 2,333 | 851,472 | 55.2 |
| July | 30,941 | 998 | 2,075 | 26.6 | 2,333 | 851,472 | 42.8 |
| August | 49,705 | 1,603 | 2,076 | 26.8 | 2,333 | 851,472 | 68.7 |
| September | 27,657 | 922 | 2,075 | 26.9 | 2,333 | 851,472 | 39.5 |
| October | 26,871 | 867 | 2,076 | 26.7 | 2,333 | 851,472 | 37.2 |
| November | 31,607 | 1,054 | 2,162 | 26.6 | 2,333 | 851,472 | 45.2 |
| December | 24,531 | 791 | 1,392 | 26.9 | 2,333 | 851,472 | 33.9 |
| Total | 419,119 | | | | 2,333 | 851,472 | 49.2 |

| Well "R" | | | | | | | |
|-----------|------------------------------|--|--|---------------------------------------|--|---|---------------|
| | Total Flow m ³ | Average Daily Flow m ³ /d | Maximum Daily Flow m ³ /d | Instantaneous Peak Flow L/s | MDWL Daily Maximum Permitted m ³ /d | MDWL Annual Permitted m ³ | % Capacity |
| January | 26,015 | 839 | 1,310 | 30.1 | 3,162 | 1,154,218 | 26.5 |
| February | 28,281 | 1,010 | 2,163 | 27.6 | 3,162 | 1,154,218 | 31.9 |
| March | 20,369 | 657 | 1,271 | 29.4 | 3,162 | 1,154,218 | 20.8 |
| April | 26,702 | 890 | 1,491 | 29.5 | 3,162 | 1,154,218 | 28.1 |
| May | 33,813 | 1,091 | 2,163 | 29.2 | 3,162 | 1,154,218 | 34.5 |
| June | 42,041 | 1,401 | 2,163 | 29.6 | 3,162 | 1,154,218 | 44.3 |
| July | 33,197 | 1,071 | 2,163 | 29.1 | 3,162 | 1,154,218 | 33.9 |
| August | 31,218 | 1,007 | 2,092 | 34.3 | 3,162 | 1,154,218 | 31.8 |
| September | 34,056 | 1,135 | 2,163 | 28.9 | 3,162 | 1,154,218 | 35.9 |
| October | 43,767 | 1,412 | 2,163 | 29.3 | 3,162 | 1,154,218 | 44.6 |
| November | 26,136 | 871 | 2,108 | 29.1 | 3,162 | 1,154,218 | 27.5 |
| December | 42,186 | 1,361 | 2,163 | 28.7 | 3,162 | 1,154,218 | 43.0 |
| Total | 387,778 | | | | 3,162 | 1,154,218 | 33.6 |

Falconbridge Drinking Water System - 240000020

The Falconbridge well system consists of 3 drilled wells:

- Well 5.
- Well 6.
- Well 7.

The system includes three pumps, disinfection with chlorine gas and polyphosphate addition for corrosion control. The wells are located north of the Sudbury Airport. Water is supplied south to the town of Falconbridge, north to the Greater Sudbury Airport reservoir and to the Nickel Rim Mine tank. CGS sells water to Glencore and two industrial clients along the south transmission line and fluoridates the water as directed by PHSD before it enters the Falconbridge municipal distribution system.

Non-Compliance with Act, Regulations, Order or Approvals

The Falconbridge DWS had two non-compliance in 2023.

- Flow was not directed to a turbidity analyzer and remote analysis was not completed in the twenty-minute allotted time frame on one occasion.
- Data was not reviewed in the mandated 72-hour time frame on one occasion. The review was completed, and no unusual data was found.

Annual Flow Summary

| Falconbridge Well #5 | | | | | | | |
|----------------------|------------------------------|--|--|-----------------------------------|--|---|---------------|
| | Total Flow m ³ | Average Daily Flow m ³ /d | Maximum Daily Flow m ³ /d | Instantaneous Peak Flow L/s | MDWL Daily Maximum Permitted m ³ /d | MDWL Annual Permitted m ³ | % Capacity |
| January | 13,314 | 429 | 1,200 | 15.3 | 1,417 | 517,280 | 30.3 |
| February | 13,187 | 425 | 1,246 | 15.3 | 1,417 | 517,280 | 33.2 |
| March | 12,160 | 392 | 1,205 | 15.2 | 1,417 | 517,280 | 27.7 |
| April | 13,635 | 440 | 1,198 | 15.1 | 1,417 | 517,280 | 32.1 |
| May | 12,154 | 392 | 1,146 | 15.4 | 1,417 | 517,280 | 27.7 |
| June | 11,442 | 369 | 1,283 | 15.3 | 1,417 | 517,280 | 26.9 |
| July | 15,382 | 496 | 1,273 | 15.3 | 1,417 | 517,280 | 35.0 |
| August | 16,902 | 545 | 1,219 | 15.2 | 1,417 | 517,280 | 38.5 |
| September | 8,383 | 270 | 1,174 | 15.3 | 1,417 | 517,280 | 19.7 |
| October | 16,005 | 516 | 1,156 | 15.1 | 1,417 | 517,280 | 36.4 |
| November | 6,720 | 217 | 1,189 | 15.1 | 1,417 | 517,280 | 15.8 |
| December | 15,816 | 510 | 1,158 | 15.3 | 1,417 | 517,280 | 36.0 |
| Total | 155,101 | | | | 1,417 | 517,280 | 30.0 |

Falconbridge Well #6

| | Total Flow m³ | Average Daily Flow m³/d | Maximum Daily Flow m³/d | Instantaneous Peak Flow L/s | MDWL Daily Maximum Permitted m³/d | MDWL Annual Permitted m³ | % Capacity |
|------------------|-------------------------------------|--|--|---|--|---|-----------------------|
| January | 8,581 | 277 | 1,257 | 16.2 | 1,417 | 517,280 | 19.5 |
| February | 8,301 | 268 | 1,199 | 16.1 | 1,417 | 517,280 | 20.9 |
| March | 8,764 | 283 | 1,212 | 16.1 | 1,417 | 517,280 | 19.9 |
| April | 8,936 | 288 | 1,225 | 17.1 | 1,417 | 517,280 | 21.0 |
| May | 7,629 | 246 | 1,342 | 16.0 | 1,417 | 517,280 | 17.4 |
| June | 16,174 | 522 | 1,304 | 16.0 | 1,417 | 517,280 | 38.0 |
| July | 9,300 | 300 | 1,244 | 15.9 | 1,417 | 517,280 | 21.2 |
| August | 8,735 | 282 | 1,202 | 15.9 | 1,417 | 517,280 | 19.9 |
| September | 13,953 | 450 | 1,293 | 16.0 | 1,417 | 517,280 | 32.8 |
| October | 3,058 | 99 | 524 | 15.7 | 1,417 | 517,280 | 7.0 |
| November | 15,190 | 490 | 1,134 | 15.7 | 1,417 | 517,280 | 35.7 |
| December | 9,779 | 315 | 1,175 | 15.8 | 1,417 | 517,280 | 22.3 |
| Total | 118,401 | | | | 1,417 | 517,280 | 22.9 |

Falconbridge Well #7

| | Total Flow m³ | Average Daily Flow m³/d | Maximum Daily Flow m³/d | Instantaneous Peak Flow L/s | MDWL Daily Maximum Permitted m³/d | MDWL Annual Permitted m³ | % Capacity |
|------------------|-------------------------------------|--|--|---|--|---|-----------------------|
| January | 9,433 | 304 | 1,010 | 13.4 | 1,417 | 517,280 | 21.5 |
| February | 7,977 | 257 | 1,017 | 13.1 | 1,417 | 517,280 | 20.1 |
| March | 12,420 | 401 | 1,001 | 13.4 | 1,417 | 517,280 | 28.3 |
| April | 9,860 | 318 | 1,009 | 12.8 | 1,417 | 517,280 | 23.2 |
| May | 14,234 | 459 | 1,008 | 12.9 | 1,417 | 517,280 | 32.4 |
| June | 8,822 | 285 | 1,021 | 13.0 | 1,417 | 517,280 | 20.7 |
| July | 12,830 | 414 | 1,009 | 12.9 | 1,417 | 517,280 | 29.2 |
| August | 9,665 | 312 | 1,015 | 12.9 | 1,417 | 517,280 | 22.0 |
| September | 12,545 | 405 | 1,004 | 12.7 | 1,417 | 517,280 | 29.5 |
| October | 13,572 | 438 | 999 | 13.0 | 1,417 | 517,280 | 30.9 |
| November | 8,049 | 260 | 883 | 12.5 | 1,417 | 517,280 | 18.9 |
| December | 7,821 | 252 | 999 | 12.6 | 1,417 | 517,280 | 17.8 |
| Total | 127,229 | | | | 1,417 | 517,280 | 24.6 |

Onaping/Levack Drinking Water System - 220003519

The Onaping/Levack system includes three drilled wells:

- Well 3.
- Well 4.
- Well 5.

The system includes three pumps, disinfection with chlorine gas, sodium hydroxide for pH adjustment, polyphosphate addition for corrosion control and fluoride injection. An elevated storage tank with re-chlorination capabilities, a pressure control/booster building with stand-by power, a pressure control facility on Fraser Crescent and the distribution piping completes the system. The City continues to monitor sodium levels in the raw water monthly due to large amounts of road salt used on a provincial highway located in close proximity to the wells.

Non-Compliance with Act, Regulations, Order or Approvals

The Onaping DWS had three non-compliance in 2023.

- A lead sample was not taken within the distribution system in 2023. Misinterpretation of the reduced sampling protocol caused an error in sample collection.
- Data was not reviewed in the mandated 72-hour time frame on one occasion. The review was completed, and no unusual data was found.
- Chlorine residual samples were not completed as required on one occasion. A communications outage resulted in remote readings being unavailable. An operator was dispatched to site to test for chlorine and no issues were found.

Annual Flow Summary

The Onaping/Levack PTTW is different from the other systems in that its total taking is not a sum of all sources, but rather the same value as any one well. For that reason, this system requires superimposing all three wells onto one chart to ensure the sum does not exceed the permit.

| Onaping Wells Total | | | | | |
|---------------------|------------------------------|--|---|--|---------------|
| | Total Flow m ³ | Maximum Daily Flow m ³ /d | MDWL Daily Maximum Permitted m ³ /d | MDWL Annual Permitted m ³ | % Capacity |
| January | 44,656 | 1,792 | 5,237 | 1,911,541 | 27.5 |
| February | 42,658 | 2,192 | 5,237 | 1,911,541 | 29.1 |
| March | 50,760 | 1,939 | 5,237 | 1,911,541 | 31.3 |
| April | 50,223 | 1,983 | 5,237 | 1,911,541 | 32.0 |
| May | 52,191 | 2,088 | 5,237 | 1,911,541 | 32.1 |
| June | 52,431 | 2,067 | 5,237 | 1,911,541 | 33.4 |
| July | 55,964 | 2,285 | 5,237 | 1,911,541 | 34.5 |
| August | 52,077 | 2,276 | 5,237 | 1,911,541 | 32.1 |
| September | 55,677 | 2,282 | 5,237 | 1,911,541 | 35.4 |
| October | 56,678 | 2,366 | 5,237 | 1,911,541 | 34.9 |
| November | 49,515 | 2,107 | 5,237 | 1,911,541 | 31.5 |
| December | 53,666 | 2,132 | 5,237 | 1,911,541 | 33.1 |
| Total | 616,495 | | 5,237 | 1,911,541 | 32.3 |

Vermilion Distribution System - 260006789

The Vermilion distribution system is a standalone distribution system that receives water from a “donor” system, as CGS purchases water from Vale, the owner of the Vermilion water treatment facility. Vale has responsibility for the treatment facility and must also comply with O. Reg. 170/03. The Vale water treatment facility is not the subject of this report.

CGS owns and operates the distribution network in the communities of Copper Cliff, Lively, Naughton, Whitefish and the Atikameksheng Anishnawbek Reserve. The system also includes the Walden Water Storage Tank and Walden Metering Chamber.

Water quality throughout the distribution systems is monitored through regular sampling in accordance with O. Reg. 170/03.

Non-Compliance with Act, Regulations, Order or Approvals

The Vermilion DWS had two non-compliances in 2023.

- Data was not reviewed on the mandated 72-hour schedule. The data was reviewed; no issues were found with the water quality.
- Chlorine residual samples were not completed as required on one occasion. A communications outage resulted in remote readings being unavailable. An operator was dispatched to site to test for chlorine and no issues were found.